



---

## ADDENDUM NO. 1

---

TO: ALL BIDDERS OF RECORD

PROJECT: **Freezeout Lake WMA Cold Storage Building (Rebid)**

FWP PROJECT #: **7179102**

DATE: **May 29, 2018**

FROM: AMES Engineering, LLC  
Electrical Design & Consulting  
815 Jade Street, Helena, MT 59602  
Phone/Fax: (406) 458-0494 e-mail:susanhames@mt.net

**Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.**

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

### MODIFICATIONS:

- 1) Sheet E1, Detail 2: In lieu of intercepting existing wiring and conduit to the existing building with the underground splice, provide all new conduit and wire from the existing main panel to new panelboard "A" in the new building.
- 2) Sheet E2, Detail 1: Delete watertight connection detail.

End of Addendum #1